

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. <i>(If applicable)</i>	
6. ISSUED BY	CODE	7. ADMINISTERED BY <i>(If other than Item 6)</i>	CODE	
8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>			(✓)	9A. AMENDMENT OF SOLICITATION NO.
				9B. DATED <i>(SEE ITEM 11)</i>
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED <i>(SEE ITEM 13)</i>
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

(✓)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER <i>(Specify type of modification and authority)</i>

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>		16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
<i>(Signature of person authorized to sign)</i>		BY _____ <i>(Signature of Contracting Officer)</i>	

PREVIOUS EDITION UNUSABLE

(5) A schedule detailing coordination of erosion control and sediment control measures with the various construction operations or stages. Include the furnishing, installation, maintaining, and removing of temporary devices and the installation of permanent erosion control features.

(6) A schedule outlining the proposed schedule of culvert replacement operations such that the area of disturbed or erodible material is minimized. Schedule the work such that temporary and permanent erosion and sediment control measures can be incorporated at the earliest practical time.

(7) Construction methods used in various items of work to minimize erosion.

Add the following:

At least 5 days prior to the preconstruction conference, designate in writing an Erosion Control Supervisor who is responsible for implementing the requirements of this Section.

When temporary erosion and sediment control measures are required due to the Contractor's negligence, carelessness, or failure to install permanent controls as part of the work in a timely manner, provide temporary measures at no cost to the Government.

**157.12 Inspection and Reporting.** Add the following:

Monitor the turbidity of waters adjacent to the project. Take turbidity measurements using an HF-DRT 15CE turbidimeter or equivalent upstream of the project and 150 meters downstream of the area of the highest turbidity. If the measurements show an increase of 10 NTU or more, immediately suspend operations in the vicinity of the problem area and modify the erosion control measures to eliminate the cause of the high turbidity. Include turbidity readings, locations, and actions taken, if any, in inspection reports. Also provide documentation of meter calibration.

**157.14 Acceptance.** Add the following:

Soil erosion control will be evaluated under Subsection 106.02 based on the demonstrated ability of the erosion control measures to result in minimal soil erosion, sedimentation and/or siltation, and turbidity increases within or adjacent to the project limits.

**Section 203. – REMOVAL OF STRUCTURES AND OBSTRUCTIONS**

**Description**

**203.01** Add the following:

This item also includes the removal of 35 sediment logs and 40 sandbags from along the existing corridor.

### Construction Requirements

**203.04 Removing Material.** Add the following:

Approximately 3,100 m of silt fence was installed during the clearing contract in 2004 and 2005 along the Beartooth Highway (KP 39.5 to KP 52.4). In those locations outside immediate construction activities, coordinate with the CO to remove the silt fence.

#### Measurement

**203.07** Add the following:

Measure for the removal of existing sediment logs and sandbags will be made by the each.

### ***Section 204. - EXCAVATION AND EMBANKMENT***

#### ***Construction Requirements***

#### ***Payment***

**204.17** Add the following:

*Geotextile Type II-A is considered subsidiary for payment to Item 20402-0000 Subexcavation.*

### **Section 303. - ROAD RECONDITIONING**

#### **Material**

**303.02** Add the following:

Crushed aggregate	703.06
-------------------	--------

#### **Construction Requirements**

**303.04 Shoulder Reconditioning.** Delete the text and substitute the following:

Place windrowed shoulder material along the shoulders to eliminate pavement edge drop offs along the edge of the pavement. Shape as necessary for drainage and appearance. Dispose of waste according to Subsection 204.14.

**303.08 Pulverizing.** Delete the text and substitute the following:

Remove vegetation adjacent to the pavement by blading each side of the roadway 300mm prior to pulverizing. Pulverize the existing asphalt pavement and underlying materials to a depth of 150 mm or 25 mm below the existing asphalt pavement depth, whichever is greater. If cobbles or boulders are